



# TEST REPORT

ASTM E84-03

## SURFACE BURNING CHARACTERISTICS

Report No. 16839 - 123020

MINCOM-PPFR

December 20, 2004

Prepared for:

Nantong Mincom Composite Materials Co. Ltd.  
No. 5 Bldg, Economic & Technologies  
Development Zone  
Nantong, Jiangsee 226009

OMEGA POINT  
LABORATORIES, INC.  
16015 Shady Falls Road  
Elmendorf, TX 78112  
(V) 210-635-8100  
(F) 210-635-8101  
800-966-5253  
[www.opl.com](http://www.opl.com)



### ABSTRACT

Test Specimen: **MINCOM-PPFR**

Test Standard: **ASTM E84-03**

Test Date: **December 17, 2004**

Test Sponsor: **Nantong Mincom Composite Materials Co. Ltd.**

Test Results:

FLAME SPREAD INDEX = 5  
SMOKE DEVELOPED INDEX = 10

123020

*This report and the information contained herein is for the exclusive use of the client named herein. Omega Point Laboratories, Inc. authorizes the client to reproduce this report only if reproduced in its entirety. The description of the test procedure, as well as the observations and results obtained, contained herein are true and accurate within the limits of sound engineering practice. These results apply only for the specimens tested, in the manner tested, and may not represent the performance of other specimens from the same or other production lots nor of the performance when used in combination with other materials. The test specimen identification is as provided by the client and Omega Point Laboratories, Inc. accepts no responsibility for any inaccuracies therein. Omega Point did not select the specimen and has not verified the composition, manufacturing techniques or quality assurance procedures. This report does not imply certification of the product by Omega Point Laboratories, Inc. Any use of the Omega Point Laboratories name, any abbreviation thereof or any logo, mark, or symbol therefor, for advertising material must be approved in writing in advance by Omega Point Laboratories, Inc. The client must have entered into and be actively participating in a Listing & Follow-up Service program. Products must bear labels with the Omega Point Laboratories Certification Mark to demonstrate acceptance by Omega Point Laboratories, Inc. into the Listing program.*



Eric G. Hutchinson  
E84 Operator

December 20, 2004

Reviewed and approved:



William E Fitch PE No. 55296

December 20, 2004





# TEST REPORT

ASTM E84-03

## SURFACE BURNING CHARACTERISTICS

Report No. 16839 - 123021

MINCOM-MPFR

December 21, 2004

Prepared for:

Nantong Mincom Composite Materials Co. Ltd.  
No. 5 Bldg, Economic & Technologies  
Development Zone  
Nantong, Jiangsee 226009

OMEGA POINT  
LABORATORIES, INC.  
16015 Shady Falls Road  
Elmendorf, TX 78112  
(V) 210-635-8100  
(F) 210-635-8101  
800-966-5253  
[www.opl.com](http://www.opl.com)



### ABSTRACT

Test Specimen: **MINCOM-MPFR**

Test Standard: **ASTM E84-03**

Test Date: **December 17, 2004**


Test Sponsor: **Nantong Mincom Composite Materials Co. Ltd.**

Test Results:

FLAME SPREAD INDEX = 5  
SMOKE DEVELOPED INDEX = 0

123021

*This report and the information contained herein is for the exclusive use of the client named herein. Omega Point Laboratories, Inc. authorizes the client to reproduce this report only if reproduced in its entirety. The description of the test procedure, as well as the observations and results obtained, contained herein are true and accurate within the limits of sound engineering practice. These results apply only for the specimens tested, in the manner tested, and may not represent the performance of other specimens from the same or other production lots nor of the performance when used in combination with other materials. The test specimen identification is as provided by the client and Omega Point Laboratories, Inc. accepts no responsibility for any inaccuracies therein. Omega Point did not select the specimen and has not verified the composition, manufacturing techniques or quality assurance procedures. This report does not imply certification of the product by Omega Point Laboratories, Inc. Any use of the Omega Point Laboratories name, any abbreviation thereof or any logo, mark, or symbol therefor, for advertising material must be approved in writing in advance by Omega Point Laboratories, Inc. The client must have entered into and be actively participating in a Listing & Follow-up Service program. Products must bear labels with the Omega Point Laboratories Certification Mark to demonstrate acceptance by Omega Point Laboratories, Inc. into the Listing program.*




Eric G. Hutchinson

E84 Operator

December 21, 2004

Reviewed and approved:



William E Fitch PE No. 55296

December 21, 2004

