

境外检测-003

**ASTM E84-00a  
SURFACE BURNING  
CHARACTERISTICS OF  
BUILDING MATERIALS**

**Nantong MINCOM, Model No. MINCOM-  
IFR (Green)**

Report No. 16586-111636

June 20, 2002

Prepared For:

Nantong MINCOM Composite Materials Co., Ltd.  
Nantong, Jiangsu, P.R. China



**ABSTRACT**

Test Material: **Nantong MINCOM, Model No. MINCOM-IFR (Green)**

Test Standard: **ASTM E 84-00a Standard Test Method for SURFACE BURNING CHARACTERISTICS OF BUILDING MATERIALS (NFPA 255, UBC 8-1, UL 723)**

Test Date: **6/14/02**


Test Sponsor: **Nantong MINCOM Composite Materials Co., Ltd.**

Test Results: **FLAME SPREAD INDEX 15**  
**SMOKE DEVELOPED INDEX 400**

*This report is for the exclusive use of the client named herein. Omega Point Laboratories, Inc. authorizes the client to reproduce this report only if reproduced in its entirety. The test specimen identification is as provided by the client and Omega Point Laboratories, Inc. accepts no responsibility for any inaccuracies therein. The description of the test procedure, as well as the observations and results obtained, contained herein are true and accurate within the limits of sound engineering practice. These results are valid only for the specimens tested and may not represent the performance of other specimens from the same or other production lots. This report does not imply certification of the product by Omega Point Laboratories, Inc. Any use of the Omega Point Laboratories name, any abbreviation thereof or any logo, mark, or symbol therefor, for advertising material must be approved in writing in advance by Omega Point Laboratories, Inc. The client must have entered into and be actively participating in a Listing & Follow-up Service program. Products must bear labels with the Omega Point Laboratories Certification Mark to demonstrate acceptance by Omega Point Laboratories, Inc. into the Listing program.*

  
Guy A. Haby  
Manager, Tunnel & Furniture Testing Services

Date: June 20, 2002

  
William E. Fitch, P.E. No. 55296  
Executive Vice President

Date: June 20, 2002



境外测试-004

**ASTM E84-00a  
SURFACE BURNING  
CHARACTERISTICS OF  
BUILDING MATERIALS**

**Nantong MINCOM, Model No. MINCOM-  
VHFR (Yellow)**

Report No. 16586-111637

June 20, 2002

Prepared For:

Nantong MINCOM Composite Materials Co., Ltd.  
Nantong, Jiangsu, P.R. China



**ABSTRACT**

Test Material:	<b>Nantong MINCOM, Model No. MINCOM-VHFR (yellow)</b>	
Test Standard:	<b>ASTM E 84-00a Standard Test Method for SURFACE BURNING CHARACTERISTICS OF BUILDING MATERIALS (NFPA 255, UBC 8-1, UL 723)</b>	
Test Date:	<b>6/14/02</b>	
Test Sponsor:	<b>Nantong MINCOM Composite Materials Co., Ltd.</b>	
Test Results:	<b>FLAME SPREAD INDEX</b>	<b>10</b>
	<b>SMOKE DEVELOPED INDEX</b>	<b>500</b>

*This report is for the exclusive use of the client named herein. Omega Point Laboratories, Inc. authorizes the client to reproduce this report only if reproduced in its entirety. The test specimen identification is as provided by the client and Omega Point Laboratories, Inc. accepts no responsibility for any inaccuracies therein. The description of the test procedure, as well as the observations and results obtained, contained herein are true and accurate within the limits of sound engineering practice. These results are valid only for the specimens tested and may not represent the performance of other specimens from the same or other production lots. This report does not imply certification of the product by Omega Point Laboratories, Inc. Any use of the Omega Point Laboratories name, any abbreviation thereof or any logo, mark, or symbol therefor, for advertising material must be approved in writing in advance by Omega Point Laboratories, Inc. The client must have entered into and be actively participating in a Listing & Follow-up Service program. Products must bear labels with the Omega Point Laboratories Certification Mark to demonstrate acceptance by Omega Point Laboratories, Inc. into the Listing program.*

  
Guy A. Haby  
Manager, Tunnel & Furniture Testing Services

Date: June 20, 2002

  
William E. Fitch, P.E. No. 55296  
Executive Vice President

Date: June 20, 2002

